


TEPLOTA	-20	-15	-7	2	7	15
TEPEL.STRATA OBJEKTU	11,8	10,2	8,3	6,3	5	3
TEPEL.VÝKON-DAIKIN-altherma 16 kW	4,5	5	7,2	10	15,5	18
TEPEL.VÝKON-WAMAK: AiWa 11 EVI S	7,09	7,93	9,53	11,05	12,89	16,19
ELEKTRO-PRÍKON-DAIKIN -altherma 16 kW	3,44	3,4	3,35	3,35	3,3	3,25
ELEKTRO-PRÍKON-WAMAK: AiWa 11 EVI S	2,82	2,84	2,86	2,7	2,43	2,51
COP-WAMAK: AiWa 11 EVI S	2,514	2,792	3,332	4,093	5,305	6,450
COP-DAIKIN -altherma 16 kW	1,308	1,471	2,149	2,985	4,697	5,538

TEPELNÝ VÝKON (kW)



COP pri teplote vykurovacej vody 35°C (kW)

